

TAMILNADU FIRE AND RESCUE SERVICES

FIRE SAFETY CERTIFICATE

R.C NO: 11 / V / VLY / 2026

DATE : 09/ 01 / 2026

No : 02/2026

Certified that the **M/S DAVE BABA VIDYALAYA** (Name of the building or premises) at **No.16 , VANDIKARAN STREET,VELACHERY , CHENNAI - 600 042** (address) comprised of Nil basement (s) **Ground First and Second Floor** (upper floors) owned / occupied **M/S DAVE BABA VIDYALAYA** (name of the institution) have complied with the fire prevention and fire safety requirements in accordance With rule of state / UT Fire Service Rules and Verified by the officer concered of fire service on **08/01/26** (date of inspection) in the presence of **Mrs. N. Palaniveluu, Correspondent , DAVe Baba Vidyalaya, No. 16 , Vandikaran Street, Velachery, Chennai - 600 042** (name and address of the Manager / Secretary or his representative) and that the building/ premises is fit for occupancy **PKG to Class XI** with effect from **09 / 01 / 2026** for a period of **One year** in accordance with rule and subject to compliance of the conditions.

1. All the Fire Extinguishers have to be recharged placement and maintained periodically as per BIS 2190/2010.
2. Periodical Maintained should be ensured to keep all fire production equipments and system always in good condition.
3. National building code-2016 Fire & Life safety part-IV should be followed.
4. Fire Drill should be conduct as per NBC-2016.

Issued On **09/01/2026** at **Velachery By**

*Strike out whichever is not applicable



TO:

**M/S DAVE BABA VIDYALAYA ,
No. 16 , Vandikaran Street ,
Velachery, Chennai - 600 042**

Copy To :

1. District Officer, Chennai City South District,
2. Station Officer , Velachery

Signature With Seal :

Name

Designation

**STATION OFFICER
VELACHERY FIRE & RESCUE STATION
CHENNAI - 600 042.**

: **D. PRABAKARAN**

: Station Officer